

# REGISTRATION OF PLANT DESIGN FOR PREFABRICATED SCAFFOLDING



Client No: 6091023

Printed: 27/09/2012

**Safe Access Solutions Pty Ltd**

**60 Wyatt Street  
ADELAIDE SA 5000**

## Contact details

### Licensing Clerk

**Address:** Level 4 Building A  
33 Richmond Road  
KESWICK SA 5035

**Postal:** GPO Box 465  
ADELAIDE SA 5001

**Phone:** 1300 365 255  
**Fax:** +61 8 8303 0411

**Website:** [www.safework.sa.gov.au](http://www.safework.sa.gov.au)

## DETAILS OF REGISTERED DESIGN

**Site Address:** 52-58 Chapel Street  
THEBARTON SA 5031  
AUSTRALIA

**Design Registration Number:** SD 00274-3

**Issued:** 13 September 2012

**Description:** Prefabricated Scaffolds - Maxiskaff  
3m length x 1.5m; 1500 series  
3m length x 1.0m; 1000 series  
3m length x 0.7m; 700 series

**Design Drawing Numbers:** A990365 SK1B, SK2B, SK3B, SK4A  
Load test report A990365-D03  
Load Test report Aztec AAD120040  
Drg DG02 H Frame 07 28/05/2012

**Designer:** Aztec Analysis

**Design Code:** AS1576:1995 Parts 1 and 3; AS1576:2010 Part 1; AS1657:1992

**Design Criteria:** 3mx1.5m, Medium Duty; 8.8m Max; 33% Brace  
3mx1.0m; Medium Duty; 6.0m Max; 33% Brace  
3mx0.7m; Medium Duty; 4.0m Max; 33% Brace

**Hazard Level:**

This is to certify that the design of the item of plant described has been registered pursuant to the Occupational Health Safety and Welfare Regulations 2010 and the National Occupational Health and Safety Standard for Plant. If this registered design is altered, it must be re-submitted for re-registration within 21 days or this registration will lapse. The Registered design number must be provided to any manufacturer, importer or supplier of the plant. The Design Registration Number: SD 00274-3 must be permanently marked on the plant. Non compliance with the regulations may incur a penalty.

Delegate of Director  
SafeWork SA, Department of Premier and Cabinet